

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, LRAA/TTHM**

The Texas Commission on Environmental Quality (TCEQ) has notified the EL OSO WSC TX 1280007 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes at **0.080** milligrams per liter (mg/L) based on locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter three 2023 of **0.088** mg/L for DBP2-01

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

El Oso is installing more automatic flush valves throughout the system, which will help reduce water age. We are also seeking technical assistance to help us identify the area or areas affected by the high TTHM levels. The water system expects to return into compliance within the next testing quarter.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, you may contact El Oso Water Supply Corporation at (830) 583-3543. Ask for Tommy De Las Santos

Posted/Delivered on November 21,2023