

WATERWORKS DISTRICT NO. 2
PARISH OF BEAUREGARD
(Beauregard District No 2, Ward No 5)

PUBLIC WATER SUPPLY ID: LA1011012



CONSUMER CONFIDENCE
ANNUAL QUALITY WATER REPORT

2024 CCR

INTENTIONALLY
LEFT
BLANK

The Water We Drink
Waterworks District No. 2
Parish of Beauregard
Public Water Supply ID: LA1011012

We are pleased to present to you the **Annual Water Quality Report for the year 2024**. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our third annual water system grade is a "110-A". Our water system **report card** can be found on our website at <https://www.waterworks2bp.org/>, >Related Links> WWD2 Water Grade 2024. Or the

Direct URL Link:

[https://clients.ruralwaterimpact.com/documents/511/Singer Water Grade 2024 36b641fb-d90f-47bd-8cbc-20e2c2503524.pdf](https://clients.ruralwaterimpact.com/documents/511/Singer_Water_Grade_2024_36b641fb-d90f-47bd-8cbc-20e2c2503524.pdf)

Our water source(s) are listed below:

Source Name	Source Water Type
Well #1—Main Plant	Ground Water
Well #2---Singer Waterworks Rd	Ground Water
Well #3---Stanley Smith (East)	Ground Water
Well #4---Stanley Smith (West)	Ground Water
Well #5---Jacobs Road-Fields Plant	Ground Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

A Source Water Assessment Plan (SWAP) is now available from our office. This plan is an assessment of a delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources. According to the Source Water Assessment Plan, our water system had a

susceptibility rating of 'MEDIUM'. If you would like to review the Source Water Assessment Plan, please feel free to contact our office.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amounts of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact PAULA ROSE OR JERRY COOLEY at 337-462-6805.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2024. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

During the period covered by this report we had the below noted violations.

Compliance Period	Analyte	Type

Our water system tested a minimum of 7 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	HighestRAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2024	1.3	ppm	0.0-1.99	4	4	Water additive used to control microbes.

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

The State of Louisiana regularly monitors source water per State and Federal Regulations. Treated water samples are monitored to further evaluate compliance

Source Water Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	3/17/2024	1.1	0 - 1.1	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
DI(2-ETHYLHEXYL) PHTHALATE	3/17/2024	0.56	0 - 0.56	ppb	6	0	Discharge from rubber and chemical factories
FLUORIDE	3/17/2024	0.2	0 - 0.2	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Source Water Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	3/17/2024	1.06	0 - 1.06	pCi/l	5	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	3/17/2024	7.27	0 - 7.27	pCi/l	50	0	Decay of natural and man-made deposits.
RADIUM-226	3/17/2024	1.06	0 - 1.06	PCI/L	5	0	Erosion of natural deposits

Lead and Copper	Date	90TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2019 - 2022	0.4	0 - 0.8	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2019 - 2022	3	0 - 4	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	4456 HWY 27	2023 - 2024	0	0	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	SNYDER RD @ HWY 389	2023 - 2024	5	5.4	ppb	60	0	By-product of drinking water disinfection
TTHM	4456 HWY 27	2023 - 2024	1	0.53	ppb	80	0	By-product of drinking water chlorination
TTHM	SNYDER RD @ HWY 389	2023 - 2024	17	17.1	ppb	80	0	By-product of drinking water chlorination

Source Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL
ALUMINUM	3/17/2024	0.01	0.01	MG/L	0.2
HARDNESS, TOTAL (AS CaCO3)	3/17/2024	10.5	3.4 - 10.5	MG/L	0
IRON	3/17/2024	0.08	0 - 0.08	MG/L	0.3
PH	3/17/2024	8.29	5.43 - 8.29	PH	8.5
POTASSIUM	3/17/2024	2	0.3 - 2	MG/L	0
SODIUM	3/17/2024	77.8	7.9 - 77.8	MG/L	0
SULFATE	3/17/2024	6	0 - 6	MG/L	250

Treated Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL
IRON	3/17/2024	0.03	0 - 0.03	MG/L	0.3

+++++Environmental Protection Agency Required Health Effects Language+++++

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

+++++Environmental Protection Agency Required Health Effects Language+++++
Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. BEAUREGARD DISTRICT NO 2 WARD NO 5 is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact BEAUREGARD DISTRICT NO 2 WARD NO 5 and JERRY COOLEY BUS Phone: 337-462-6805. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Waterworks District 2 (Singer Water) has completed the Lead Service Line Inventory as required by the EPA as of October 16, 2024. This inventory was completed with no lead findings using historical engineering drawings, and documents, visual and excavation methods, as well as historical knowledge from our customers, and previous employees. A hard copy of the results will be made available to customers upon request by calling our office at 337-462-6805, or in person at 9252 Hwy 27, Singer, LA

Additional Required Health Effects Language:

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

There are no additional required health effects violation notices.

+++++
Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

++++Our water system at Beauregard District No 2, Ward 5 (Waterworks District No 2, Parish of Beauregard) has worked endlessly to improve water quality for our customers, by continually providing safe and high-quality water. In 2022 our system was awarded the Louisiana Energy Conservation System of the Year-South for our outstanding efforts in Energy Conservation++++

Direct URL Link to our CCR:

https://clients.ruralwaterimpact.com/documents/511/CCR_2023-LA1011012__in_2024_.pdf

We at the BEAUREGARD DISTRICT NO 2 WARD NO 5 work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. Please call our office if you have questions.